

THE NEW LIFT CO.

3/80 Edinburgh Rd, Marrickville NSW 2204

Elevator Fire Safety Measures

1 Building of Concern

#	Street:	Suburb:	Postcode:
15	Alberta St	Sydney	NSW 2000
Building Name:		Building Use:	
Aspire Apartments		Apartment Block	
Owner/s:			
SP 91667 C/O Strata Republic			
Owner/s Address:			
#	Street:	Suburb:	Postcode:
suite 704, level 7, 70	pitt street,	sydney	NSW 2000
Managing Agent:			
Strata Republic			

2 TNLC Contact

Service Coordinator	Isabella Mora – Ponce
Contact No.:	0457 440 062

3 Fire Safety Measure

The following Fire Safety Measures (FSM) relate to the lifts in the abovementioned building and the specific lifts nominated.		
Lift No/s.: 1		
FSM:	Standard/s:	Date:
Fire-rated Landing Doors	AS1735.11-1986, C3.10	8. 06. 2023
Fire Service Controls	AS1735.1 / AS1735.2, E3.7 / E3.9 / E3.10	8. 06. 2023

The above FSM were assessed on the above date as being compliant to the standard/s nominated.

Signed: Tapiwa Sithole

Name: Tapiwa Sithole

Date: June 30, 2023

Note – The New Lift Company Pty Ltd have not signed this document in the capacity of a ‘Competent Fire Safety Practitioner’ and that the assessment on the landing doors is based on the tag stating the fire rating to AS1735.11 and no obvious changes have been made to the construction of the landing doors